

# COMMUNITY HEALTH CENTRE, KURATHIKAD

THEKKEKKARA P.O, MAVELIKKARA, ALAPPUZHA, PIN 690107

Phone : 0479 2328476 email : [chckurathikad@gmail.com](mailto:chckurathikad@gmail.com)

8A/2023

31.03.2023


## SANITATION CERTIFICATE

This is to certify that Sree Narayana Central School, Cherukunnam, Thekkekkara P.O, Mavelikkara had been inspected by our Public Health staff on 30.03.2023 and found that general Hygiene arrangements are satisfactory.

The wash rooms and latrines are well maintained. Safe drinking water is also provided.

  
Health Inspector  
Community Health Centre  
Kurathikadu



  
MEDICAL OFFICER IN-CHARGE  
Community Health Centre  
Kurathikad, Thekkekkara  
Mavelikkara-690.107

# COMMUNITY HEALTH CENTRE, KURATHIKAD

THEKKEKKARA P.O, MAVELIKKARA, ALAPPUZHA, PIN 690107

Phone : 0479 2328476 email : [chckurathikad@gmail.com](mailto:chckurathikad@gmail.com)

04/2023

31.03.2023


## SANITATION CERTIFICATE

This is to certify that Sree Narayana Central School, Cherukunnam, Thekkekkara P.O, Mavelikkara had been inspected by our Public Health staff on 30.03.2023 and found that general Hygiene arrangements are satisfactory.

The wash rooms and latrines are well maintained. Safe drinking water is also provided.

  
Health Inspector  
Community Health Centre  
Kurathikadu



  
MEDICAL OFFICER IN-CHARGE  
Community Health Centre  
Kurathikad, Thekkekkara  
Mavelikkara-690.107



# QUALITY CONTROL SUB DISTRICT LAB

## KERALA WATER AUTHORITY KAYAMKULAM



TC-10689

Email [aqcsdlkylm@gmail.com](mailto:aqcsdlkylm@gmail.com)

ULR-TC 10689230000099F

### WATER ANALYSIS REPORT

Report No:402/A/2023	Date:29/03/2023
----------------------	-----------------

<b>Customer Name &amp; Address</b> Sree Narayana Central School Cherukunnam Thekkekara P O Mavelikkara	1.Date of Receipt	: 20/03/2023
	2.Sampling done by	: Customer
	3.Sample Code	: 2023/QCSDL/KYLM/A 402
	4.Source of Sample	: Open Well
	5.Sample Quantity	: 1 Lr
	6.Test performing dates	From:22/03/2023 To:23/03/2023

Sl. No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Test Method	Result
1	Turbidity	(NTU)	1	IS 3025(part10)-1984 (Reaffirmed 2017)	0.11
2	pH at $-25-^{\circ}\text{C}$	-	6.5-8.5	IS 3025(part 11)-1983 (Reaffirmed 2017)	6.543
3	Total Hardness (as $\text{CaCO}_3$ )	(mg/litre)	200	IS 3025(part21)-2009 (Reaffirmed 2019)	116
4	Chloride(as Cl)	(mg/litre)	250	IS 3025(part32)-1988 (Reaffirmed 2019)	27.991

Verified By

Authorized by

Deputy Quality Manager  
Quality Control  
Kayamkulam Lab

**NB:** The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except in full without the written approval of the Laboratory.

Sample will be retained only for 7 days after completion of analysis  
Sampling is not done by the Lab





**QUALITY CONTROL SUB DISTRICT LAB**  
**KERALA WATER AUTHORITY**  
**KAYAMKULAM**

Email : acqcsdlkylm@gmail.com

**WATER ANALYSIS REPORT**

<b>Report No:402/A/2023</b>	<b>Date:29/03/2023</b>
-----------------------------	------------------------

<b>Customer Name &amp; Address</b>	1.Date of Receipt	: 20/03/2023
<b>Sree Narayana Central School Cherukunnam Thekkekara P O Mavelikkara</b>	2.Sampling done by	: Customer
	3.Sample Code	: 2023/QCSDL/KYLM/A 402
	4.Source of Sample	: Open Well
	5.Sample Quantity	: 1 Lr
	6.Test performing dates	From:22/03/2023

Sl. No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Test Method	Result
1	Electrical conductivity at ...25... °C	(micro mhos/cm)	-	IS 3025(part14)-2013 (Reaffirmed 2019)	303.1
2	Iron (as Fe)	(mg/litre)	1	-	BDL
3	Nitrate (as NO <sub>3</sub> )	(mg/litre)	45	-	5

Verified By

Authorized by

**Deputy Quality Manager**  
**Quality Control Sub District Lab**  
**Kayamkulam, KWA**

**NB:** The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except in full without the written approval of the Laboratory.

Sample will be retained only for 7 days after completion of analysis  
Sampling is not done by the Lab  
BDL- Below Detection Limit



QUALITY CONTROL SUB DISTRICT LAB  
KERALA WATER AUTHORITY  
KAYAMKULAM

Email : aeqcSDLkylm@gmail.com

## WATER ANALYSIS REPORT

Report No:402/A/2023	Date:30/03/2023
----------------------	-----------------

Customer Name & Address Sree Narayana Central School Cherukunnam Thekkekara P O Mavelikkara	1.Date of Receipt	: 20/03/2023
	2.Sampling done by	: Customer
	3.Sample Code	: 2023/QCSDL/KYLM/A 402
	4.Source of Sample	: Open Well
	5.Sample Quantity	: 100 ml
	6.Test performing dates	From:22/03/2023 To:27/03/2023


### BACTERIOLOGICAL ANALYSIS

No	Parameters	Acceptable limits as per – IS 10500 - 2012	Test Method	Result
1	Coliforms	Shall not be detected/100 ml	IS15185:2016	Absent
2	E-coli	Shall not be detected/100 ml	IS15185:2016	Absent

Remarks:-

NB:-The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Test Method :  
Coliform – Membrane Filtration Method  
E- coli - Membrane Filtration Method



*[Signature]*  
Authorized by

End of the report

Page 3-3